

Safety/Energy Committee Minutes Held In-Person; November 19, 2024

Present: Michelle Sides, Jessica Olson, Mike Hanson, Mark Lilley, Mike Komes, Mike McGlade and Crystal Contreras.

Absent: Rebecca Chiles, Adria Henrickson, Chelsee Blatner, Nora Solvedt, Jacquyn Vasquez, Zachary Hammerle, Julie Grammer, and Beeb Singsin.

Meeting was called to order at 1402 hrs.

Review of Minutes:

- Mike Hanson made the motion to approve, Mark Lilley seconded.
- June 18 minutes approved.

Building Fire life Safety Inspections: Jessica Olson

November 2024

Extinguisher Issues:

- Many buildings are not receiving their monthly checks.
- Natural Science, Rice, and Advising Center have an extinguisher needing replacing.
- Replaced two extinguishers in HSS.

Fire Panel/Alarm Issues:

- Advising Center, HSS, and Cottage – Fire panel batteries due for replacement. CDC IP dialer batteries need replaced.
- DeVolder – Horn/strobe not working outside room 123.
- Rice – Alarm bell not working outside room 110D.

Sprinkler Issues:

- Campbell – Sprinkler heads above kiln need replaced with 286 degree heads.

Electrical Issues:

- Watson – White mini-fridge plugged into a power strip.
- DeVolder – Battery back-up chirping.

Light Issues:

- Rice – Emergency light outside 105 needs batteries replaced.
- HWC – Several lights out on third floor landing area near staircase.

Ceiling Tile Missing/Holes Needing Closed:

- OPE – Large hole in wall outside 113.
- Rice – 5" holes in catwalk area.
- HSS – Ceiling tile above 1st floor drinking fountain is offset.

Tipping Hazards:

- OPE – Rooms 112 and 113 have shelving and cabinets needing secured.
- Todd – Metal storage cabinet in 021 needs secured.

- Todd – Empty bookshelf being stored outside room 228 creating tipping hazard.

Other:

- Fume hoods in DeVolder and NS still require testing.
- DeVolder – Elevator phone didn't properly connect.
- Terry – Hole chewed through mesh crawlspace cover.

Injury Review: None this month

Energy Conservation Update:

- Upgrades approved for the New PE Rubber Room.

Round Table:

- Be careful with so many leaves on the floor, it could be slippery.
- Tree lights are up, Tree lighting Dec 6th.
- Sidewalks and cross walks need paint retouch.
- Disability ramp at the WUC was approved to be fixed.
- Space heaters need to be plugged in directly to an outlet.

Next Meeting: Dec 17th, 2024, 2pm, in Hamersly Library 205.

Meeting adjourned at 1417 hrs.